



Product Service

CERTIFICATE

No. Z10 002759 0001 Rev. 00

Holder of Certificate: Chongqing Chuanyi Automation Co.,Ltd
Actuator Filiale
Huangshan Road 61#, North New Region,
401121 Chongqing
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: Safety components
Electric Actuator

Model(s): M8000 series

Parameters: Safety function ESD (SIL2 SC3 for 1oo1 architecture,
SIL3 for 1oo2 architecture)

Tested according to: EN 61508-1:2010
EN 61508-2:2010
EN 61508-3:2010
IEC 61508-1:2010
IEC 61508-2:2010
IEC 61508-3:2010
IEC 61511-1:2016
EN 61511-1:2017

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: CC101748C
Valid until: 2028-11-21
Date, 2023-11-22

(Christian Dirmeier)